

## G59/3 (RoCoF amendment) Type Test Report – SE25K – SE27.6K

Engineering Recommendation G59/3				
Type Tested Reference Number 15PP010-05		15PP010-05		
Generating U	Generating Unit Technology		Photovoltaic Inverter	
Manufacturer		SolarEdge Technologies Ltd		
Address		1 HaMada Street Herzeliya 4673335 Israel		
Tel	+972-9-957-6620	Fax +972-9-957-6591		
Email	info@solaredge.com	Website <u>www.solaredge.com</u>		

I certify on behalf of the company named above as a supplier of a Generating Unit, that all products supplied by the company with the above Type Test reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of G59/3

Herzeliya Israel June 25 2018

PLACE Date Meir Adest, VP Core Technologies

Generating Unit	SE25K	SE27.6K
Rated AC Power (kW)	25	27.6

Note: All test results stated in the following document are obtained from testing the largest inverter covered by this Type Test Report. All smaller inverters named on this report will be equivalent values.



	Harmonics							
	Generator tested to BS EN 61000-3-2							
	50% of rat	ed output	100% of ra	ted output	BS EN 61000-3- A	2 Limit Class		
Harmonic	Result (A)	Result (%)	Result (A)	Result (%)	1 Phase	3 Phase		
2nd	0.076	0.190	0.172	0.430	8 %	8 %		
3rd	0.120	0.300	0.320	0.820	21.6 %	Not stated		
4th	0.076	0.190	0.180	0.450	4 %	4 %		
5th	0.484	1.210	0.336	0.840	10.7 %	10.7 %		
6th	0.036	0.900	0.112	0.280	2.67 %	2.67 %		
7th	0.468	1.170	0.268	0.670	7.2 %	7.2 %		
8th	0.020	0.050	0.032	0.080	2 %	2 %		
9th	0.060	0.150	0.080	0.200	3.8 %	Not stated		
10th	0.012	0.030	0.032	0.080	1.6 %	1.6 %		
11th	0.272	0.680	0.220	0.550	3.1 %	3.1 %		
12th	0.012	0.030	0.016	0.040	1.33 %	1.33 %		
13th	0.196	0.490	0.204	0.510	2 %	2 %		
THD	-	3.97	-	1.898	23 %	13 %		
PWTHD	-	2.786	-	3.095	23 %	22 %		



DC Current Injection					
Test Power Level	10 % 55 % 100 %				
Limit	0.25 %				
Result	0.08 %	0.10 %	0.10 %		

Power Factor						
Test Voltage	216.2 V	230 V	253 V			
Limit		> 0.95				
Result	0.99	0.99	0.99			

Frequency Tests							
C atia .a	Set	Setting		sult	No Trip Test		
Function	Frequency	Time Delay	Frequency	Time Delay	Test Value	Result	
O/F Stage 1	51.5 Hz	90 sec	51.5 Hz	90.03 sec	51.3 Hz for 95 sec	No trip	
O/F Stage 2	52 Hz	0.5 sec	52.0 Hz	0.540 sec	51.8 Hz for 89.98 sec	No trip	
					52.2 Hz for 0.48 sec	No trip	
U/F Stage 1	47.5 Hz	20 sec	47.5 Hz	20.03 sec	47.7 Hz for 25 sec	No trip	
U/F Stage 2	47 Hz	0.5 sec	47.0 Hz	0.525 sec	47.2 Hz for 19.98 sec	No trip	
					46.8 Hz for 0.48 sec	No trip	

Voltage Tests							
Function	Set	Setting		sult	No Trip Test		
Function	Voltage	Time Delay	Voltage	Time Delay	Test Value	Result	
O/V Stage 1	262.2 V	1 sec	261.7 V	1.013 sec	258.2 V for 2 sec	No trip	
O/V Stage 2	273.7 V	0.5 sec	273.2 V	0.511sec	269.7 V for 0.98 sec	No trip	
					277.7 V for 0.48 sec	No trip	
U/V Stage 1	200.1 V	2.5 sec	200.0 V	2.515 sec	204.1 V for 3.5 sec	No trip	
U/V Stage 2	184 V	0.5 sec	183.9 V	0.514 sec	188 V for 2.48 sec	No trip	
					180 V for 0.48 sec	No trip	



Loss of Mains and Single Phase Tests						
LoM methods		RoCoF				
Test Power and Imbalance	33 % -5 % Q Test 22	66 % -5 % Q Test 12	100 % -5 % Q Test 5	33 % 5 % Q Test 31	66 % 5 % Q Test 21	100 % 5 % Q Test 10
Limit	500 msec					
Result - RoCoF	288 msec	265 msec	199 msec	149 msec	181 msec	226 msec
Phase Removed			1	2	3	
Result			Trip	Trip	Trip	

Protection. Frequency change, RoCoF Stability test					
Ramp range	Test frequency	Test	Confirm no		
Kamprange	ramp	Duration	trip		
49.0Hz to 51.0Hz	+0.95Hzs <sup>-1</sup>	2.1s	Pass		
51.0Hz to 49.0Hz	-0.95Hzs <sup>-1</sup>	2.1s	Pass		

Re-connection Timer						
Timer	Delay Setting	20 sec	Measured Delay	29 sec		
Test Value	266.2 V	196.1 V	47.4 Hz	51.6 Hz		
Result	No re-connect	No re-connect	No re-connect	No re-connect		



	Fault Level Contribution					
Time after fault	Volts	Amps				
20 msec	54.4 V	38.9 A				
100 msec	52.9 V	39.9 A				
250 msec	52.6 V	39.6 A				
500 msec	21.1 V	0.1 A				
Time to trip	0.48 sec					

Self monitoring - Solid State Switching			
It has been verified that in the event of the solid state switching device failing to	Result		
disconnect the Generating Unit, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 seconds.	NA		